

St. Edwards
Building and Grounds
February 6th, 2017

Fr. Bullock	H	Schneider, Jim	H	Freese, Fred	A
Aaron Becker	E	Schons, Wes	E	Robert, Bill	H
Larsen, James	H	Armstrong, Ron	E	Judas, Roger	H
Larsen, Ray	H	Anderkay, Glen	A	Reichert, Russ	H
Schott, Al	H	Sean Schott	E	Schons, Dick	H
Jamason, Todd	E	Reichert, Russ	H		

ANNOUNCEMENTS:

- Bob Tujetsch has stepped down from B&G meeting. Thank you for your time
- Building inspections due

NEW LIFE CENTER

- Audit is in and has a few cracked windows, but they are not a factor in the over all operations of the building.

CHURCH

- Both handicapped bathrooms are fixed thanks to Jim and Russ.
- No word yet on the lighting panel.
- Mid America gave an energy audit with some reduced rates
- Discussion on steps: Stetsons has a product (several steps to it) that we could apply after doing some repair work.
- There are several steam valves that need to be replaced at a high cost. Russ will look into other vendors for supplies.

SCHOOL

- Aaron would like someone else to help him with the building
- One of the boilers had to have two tubes replaced and should have all done. Jim will call WBS and ask about cost. One boiler was built in 1953 and the other one we are not sure of, probable built earlier.

Parish Center

- Mid America audit gave some suggestions and products.

GROUNDS

- Some of the sidewalks are in need of replacing. Because of the large amount of rain in January there is standing water.

Next meeting March.

Motion to adjourn first by Bill second by Russ meeting adjourned at 1726

Respectfully Ann Schott